



NOZZLE SCHEDULE

MARK	QTY	SIZE / RATING	DESCRIPTION
N1	1	2"150# NPT	INLET
N2	1	2"150# NPT	OUTLET
N3	2	1/2" 3000# NPT	PRESS GA
N4	1	1/2" 3000# NPT	VENT
N5	1	1/2" 3000# NPT	CLEAN DRAIN
N6	1	1/2" 3000# NPT	DIRTY DRAIN

VESSEL DESIGN CONDITIONS

CODE: BEST COMMERCIAL PRACTICE			
M.A.W.P.:	150 PSI @ 250°F	M.D.M.T.:	-20° F @ 150 PSI
M.A.E.P.:	15 PSI @ 250°F		
CORROSION ALLOWANCE:	NONE	HYDROTEST PRESS:	150 PSI
STAMP:	XX	SERVICE:	NON LETHAL
PWHT:	N/A	RADIOGRAPHY:	N/A
MATERIAL:	SS304/L	GASKET:	BUNA-N

NOTES:

- VESSEL WILL HOUSE (QTY=5) 2.5" OD x 10" LG CARTRIDGES.

<p>THIRD ANGLE PROJECTION</p>		<p><b>FIL-TREK CORPORATION</b> CAMBRIDGE ONTARIO - CANADA</p> <p>www.fil-trek.com • Tel: 519.623.7448 • Fax: 519.623.8807</p>			
<p>TOLERANCES-UNLESS OTHERWISE NOTED</p> <p>DECIMAL .X = ±.1" .XX = ±.02" .XXX = ±.005"</p> <p>FRACTIONAL <math>\leq 24"</math> = ±1/16" <math>&gt; 24"</math> = ±1/8"</p> <p>ANGULAR = ± 1°</p> <p>MAX. MACHINED SURFACE FINISH 125/√</p>		<p>THIS DRAWING IS THE PROPERTY OF FIL-TREK CORPORATION AND MUST NOT BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE CORPORATION</p>			
EQUIPMENT:		CARTRIDGE FILTER HOUSING (AQ SERIES)			
MODEL NO:		S4EAQ08-005-1-2P-VB			
CUSTOMER:		-			
PARENT: NONE	DRAWN: TN	DATE: JULY 5 2012	JOB No. V-6089	DWG. No. 001 021 00017 000	REV. No. 0
PAGE: 1 OF 4	CHK'D: PT	SCALE: NTS			