




NOZZLE SCHEDULE			
MARK	QTY	SIZE / RATING	DESCRIPTION
N1	1	2" 150# NPT	INLET
N2	2	2" 150# NPT	OUTLET
N3	2	1/2" 3000# NPT	PRESSURE GAUGE
N4	1	1/2" 3000# NPT	VENT
N5	-	-	-
N6	-	-	-

VESSEL DESIGN CONDITIONS			
CODE: BEST COMMERCIAL PRACTICE			
M.A.W.P.:	150 PSI @ 250°F	M.D.M.T.:	-20° F @ 150 PSI
M.A.E.P.:	15 PSI @ 250°F		
CORROSION ALLOWANCE:	NONE	HYDROTEST PRESS:	150 PSI
STAMP:	NC	SERVICE:	NON LETHAL
PWHT:	N/A	RADIOGRAPHY:	N/A
MATERIAL:	CS	GASKET:	BUNA-N

NOTES:

1. VESSEL WILL HOUSE (QTY=1) SINGLE LENGTH BASKET.
2. DRY WEIGHT: 68 LBS
3. FLOODED WEIGHT: 140 LBS
4. SHIPPING WEIGHT: 100 LBS
5. VESSEL VOLUME: 1.0 FT<sup>3</sup>



SECTION A-A  
SCALE 1 : 12

<p>THIRD ANGLE PROJECTION</p> <p>TOLERANCES-UNLESS OTHERWISE NOTED</p> <p>DECIMAL .X = ±.1" .XX = ±.02" .XXX = ±.005"</p> <p>FRACTIONAL = ±1/8"</p> <p>ANGULAR = ± 1°</p> <p>MAX. MACHINED SURFACE FINISH 125/√</p>	<p><b>FIL-TREK CORPORATION</b></p> <p>55 Stafford Court Cambridge, Ontario N1T 1B3 Canada</p> <p>Phone: (519) 623-7448 Fax: (519) 623-8807 Email: info@fil-trek.com Website: www.fil-trek.com</p>	
	<p>THIS DRAWING IS THE PROPERTY OF 'FIL-TREK CORPORATION' AND MUST NOT BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE CORPORATION</p>	
EQUIPMENT:		BAG FILTER HOUSING (ESL SERIES)
MODEL NO:		ESL111-2P-SW-CD-150
CUSTOMER:		STOCK
PARENT:	DRAWN: TS	DATE: 31/03/2015
CHK'D: CW	SCALE: NTS	SERIAL No. Part No. 002001-20036
		DWG. No. 002001-20036-1
		REV. No. 0