







NOZZLE SCHEDULE			
MARK	QTY	SIZE / RATING	DESCRIPTION
N1	1	2" ANSI 150	INLET
N2	1	2" ANSI 150	OUTLET
N3	2	1/2" NPT CL3000	PRESSURE GAUGE
N4	1	1/2" NPT CL3000	VENT
VESSEL DESIGN CONDITIONS			
CODE: ASME SECTION VIII DIV. 1, 2017 EDITION			
M.A.W.P.: 150 PSI @ 400°F		M.D.M.T.: -20° F @ 150 PSI	
M.A.W.P.: FV PSI @ 400°F			
CORROSION ALLOWANCE: -		HYDROTEST PRESS: 195 PSI	
STAMP: UM		SERVICE: WATER	
PWHT: N/A		RADIOGRAPHY: N/A	
MATERIAL: SS304		GASKET: BUNA	

Notes

- Vessel will house 1 double length bag filter



SECTION N-N

 THIRD ANGLE PROJECTION		 FIL-TREK CORPORATION 55 Stafford Court Cambridge, Ontario N1T 1B3 Canada Phone: (519) 623-7448 Fax: (519) 623-8807 Email: info@fil-trek.com Website: www.fil-trek.com		THIS DRAWING IS THE PROPERTY OF 'FIL-TREK CORPORATION' AND MUST NOT BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE CORPORATION	
TOLERANCES-UNLESS OTHERWISE NOTED					
DECIMAL	.X == ±.1" .XX == ±.02" .XXX == ±.005"				
FRACTIONAL	== ±1/8"	EQUIPMENT: TOP LINE SINGLE BAG FILTER HOUSING			
ANGULAR	== 1°	MODEL NO: S4TL112-2F-275			
MAX. MACHINED SURFACE FINISH	125 	CUSTOMER:			
PARENT: NONE	DRAWN: AJ	DATE: 10/05/2019	SERIAL No.	Part No. 002006-00033	REV. No. 0
	CHK'D:	SCALE: NTS			