







NOZZLE SCHEDULE			
MARK	QTY	SIZE / RATING	DESCRIPTION
N1	1	2" ANSI 150	INLET
N2	1	2" ANSI 150	OUTLET
N3	2	1/2" NPT CL3000	PRESSURE GAUGE
N4	1	1/2" NPT CL3000	VENT
VESSEL DESIGN CONDITIONS			
CODE: ASME SECTION VIII DIV. 1, 2017 EDITION			
M.A.W.P.:	150 PSI @ 400°F	M.D.M.T.:	-20° F @ 150 PSI
M.A.W.P.:	FV PSI @ 400°F		
CORROSION ALLOWANCE:	-	HYDROTEST PRESS:	195 PSI
STAMP:	UM	SERVICE:	WATER
PWHT:	N/A	RADIOGRAPHY:	N/A
MATERIAL:	SS316	GASKET:	BUNA

Notes

- Vessel will house 1 double length bag filter



SECTION M-M

 THIRD ANGLE PROJECTION		 FIL-TREK CORPORATION 55 Stafford Court Cambridge, Ontario N1T 1B3 Canada Phone: (519) 623-7448 Fax: (519) 623-8807 Email: info@fil-trek.com Website: www.fil-trek.com		THIS DRAWING IS THE PROPERTY OF 'FIL-TREK CORPORATION' AND MUST NOT BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE CORPORATION	
TOLERANCES-UNLESS OTHERWISE NOTED		EQUIPMENT: TOP LINE SINGLE BAG FILTER HOUSING			
DECIMAL .X = ±.1" .XX = ±.02" .XXX = ±.005"		MODEL NO: S6TL112-2F-275			
FRACTIONAL = ±1/8"		CUSTOMER:			
ANGULAR = ± 1°		DRAWN: AJ DATE: 10/05/2019			
MAX. MACHINED SURFACE FINISH 125/√		SERIAL No.		Part No. 002006-00034	
PARENT: NONE		CHK'D:		SCALE: NTS	
				REV. No. 0	