







NOZZLE SCHEDULE			
MARK	QTY	SIZE / RATING	DESCRIPTION
N1	1	2" ANSI 150	INLET
N2	1	2" ANSI 150	OUTLET
N3	2	1/2" NPT CL3000	PRESSURE GAUGE
N4	1	1/2" NPT CL3000	VENT
VESSEL DESIGN CONDITIONS			
CODE: ASME SECTION VIII DIV. 1, 2017 EDITION			
M.A.W.P.: 150 PSI @ 400°F		M.D.M.T.: -20° F @ 150 PSI	
M.A.W.P.: FV PSI @ 400°F			
CORROSION ALLOWANCE: -		HYDROTEST PRESS: 195 PSI	
STAMP: UM		SERVICE: WATER	
PWHT: N/A		RADIOGRAPHY: N/A	
MATERIAL: CS		GASKET: BUNA	

Notes

- Vessel will house 1 double length bag filter



SECTION N-N

 THIRD ANGLE PROJECTION		 FIL-TREK CORPORATION 55 Stafford Court Cambridge, Ontario N1T 1B3 Canada Phone: (519) 623-7448 Fax: (519) 623-8807 Email: info@fil-trek.com Website: www.fil-trek.com	
TOLERANCES-UNLESS OTHERWISE NOTED		THIS DRAWING IS THE PROPERTY OF "FIL-TREK CORPORATION" AND MUST NOT BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE CORPORATION	
DECIMAL X = ±.1" .XX = ±.02" .XXX = ±.005"		EQUIPMENT: TOP LINE SINGLE BAG FILTER HOUSING	
FRACTIONAL = ±1/8"		MODEL NO: TL112-2F-275	
ANGULAR = ± 1°		CUSTOMER:	
MAX. MACHINED SURFACE FINISH 125/√		DRAWN: AJ DATE: 10/05/2019	
PARENT: NONE		SERIAL No.	Part No. 002006-00035
CHK'D:		SCALE: NTS	REV. No. 0